



NOTES:

1. GRANULAR DRAINAGE FILL SHALL BE 4" MIN' 3/4" OPEN GRADED "STALITE" POROUS PAVEMENT STRUCTURAL FILL (DEPTH VARIES WITH SLOPE OF STRUCTURAL SLAB). OMIT WHERE SECTION IS LESS THAN 4" AND BEDDING COURSE IS LAID DIRECTLY ON DRAINAGE MAT.
2. BEDDING COURSE SHALL BE 1" MINIMUM OF LIGHTWEIGHT 1/4"-3/8" WASHED FRACTURED OPEN GRADED #89 AGGREGATE BY CAROLINA STALITE OR APPROVED SUBSTITUTE
3. DRAINAGE MAT: J-DRAIN GRS OR ENKADRAIN 3615R OR APPROVED SUBSTITUTE. COORD WITH ARCHITECT AND TYPE OF WATERPROOFING TO MAINTAIN ALL ROOFING WARRANTIES.
4. CONTRACTOR TO SUBMIT ALL DRAINAGE PARTS AND ASSEMBLIES FOR APPROVAL